

Measuring Temperature in °C	Permissible Deviation – Class A		Permissible Deviation – Class B	
	Ω	C	Ω	C
-200	± 0.24	± 0.55	± 0.56	± 1.3
-100	± 0.14	± 0.35	± 0.32	± 0.8
0	± 0.06	± 0.15	± 0.12	± 0.3
100	± 0.13	± 0.35	± 0.30	± 0.8
200	± 0.20	± 0.55	± 0.48	± 1.3
300	± 0.27	± 0.75	± 0.64	± 1.8
400	± 0.33	± 0.95	± 0.79	± 2.3
500	± 0.38	± 1.15	± 0.93	± 2.8
600	± 0.43	± 1.35	± 1.06	± 3.3
650	± 0.46	± 1.45	± 1.13	± 3.6
700	-	-	± 1.17	± 3.8
800	-	-	± 1.28	± 4.3
850	-	-	± 1.34	± 4.6